

Domestic Water User Notice June 20, 2016

The Oakdale Irrigation District (OID) has recently completed the twenty seventh annual Consumer Confidence Report of your drinking water. Federal and state laws require that purveyors of domestic water send these reports to all customers each year. This law applies to OID because it is a purveyor of domestic water to the OID Rural Water System Number 1 and is the trustee for the water systems for Improvement Districts Number 22, 41, 45, 46, 49, and 51.

Specific information about the standards and the test results of your water are provided in the enclosed report.

GENERAL INFORMATION

The source of domestic water supply can be from surface water or groundwater. Presently, your water is supplied from deep wells taking groundwater from the Modesto groundwater basin; it can be delivered to you untreated and meets both state and federal drinking water standards.

If in the future, the groundwater will require treatment to meet state and federal drinking water standards. If it becomes necessary to obtain water from surface sources, the State Water Resources Control Board will require that OID construct and operate a water treatment facility. The facility, in compliance with state and federal safe drinking water standards would be required to filter, treat, and disinfect the water prior to use.

NEW WATER QUALITY STANDARDS

The U.S. Safe Drinking Water Act of 1974, as amended, is intended to ensure the quality of our nation's drinking water. The Act is administered by the U.S. Environmental Protection Agency (USEPA), which sets minimum standards and monitoring requirements for water systems. The law is enforced in California by the State Water Resources Control Board, which has the option of setting state standards more stringent than federal standards.

WATER QUALITY CONTROL

Samples from the wells and the delivery system have been routinely collected by the OID'S Water Utilities Department and are tested in state certified laboratories. OID'S routine water testing program, routine system inspections and preventative maintenance practices assure safe drinking water for you, your family and your guests. The information included in this report is for the period of January 1, to December 31, 2015.

In California, there are two categories of drinking water standards:

- 1. Primary drinking water standards: These standards are designed to protect public health, and specify limits for constituents in water that may be harmful to humans if consumed in excess. These primary MCL'S, specific treatment techniques adopted in lieu of primary MCL'S, and monitoring and reporting requirements for MCL'S that are specified in regulation.
- 2. <u>Secondary drinking water standards</u>: Relate to aesthetic qualities such as taste, odor and color.

If you have any questions regarding your water quality or this report, please contact the Oakdale Irrigation District's Water Utilities Department at (209) 840-5510, or attend any regularly scheduled meeting of the Board of Directors. The Board meetings are normally held at 9:00 A.M. on the first and third Tuesday of each month.

Sincerely.

OAKDALE IRRIGATION DISTRICT

	2015 Consumer	Confidenc	e Report				
Water System Name:	OID - ID #41 (Mountain Vie		Report Date				
We test the drinking wa of our monit	oring for the period of January I - Dec	ember 51, 2013	i ana may moi				
	Este informe contiene información Tradúzcalo ó hable con	alguien que lo	entienda bie	n			
Type of water source(s)	in use: Groundwater Well						
Name & general location	n of source(s): Well #2 on Tioga /	Ave.	<u></u>				
Drinking Water Source	Assessment information: Compl	eted in June of	2002 - see last	page			
Time and place of regu	arly scheduled board meetings for publ	ic participation	: No	ne			
	contact: Joe Buila		Phone:	(209) 847-0341			
For more information, o		D IN THIS RE	PORT				
of a contaminant that Primary MCLs are set a lis economically and te MCLs are set to protect drinking water. Maximum Contamination of a contaminant in drinking water.	nt Level (MCL): The highest level t is allowed in drinking water. s close to the PHGs (or MCLGs) as chnologically feasible. Secondary the odor, taste, and appearance of nt Level Goal (MCLG): The level aking water below which there is no	Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements. Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.					
known or expected risk U.S. Environmental Pro	to health. MCLGs are set by the tection Agency (USEPA).	Treatment reduce the	Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.				
Public Health Goal (P drinking water below w risk to health. Ph	HG): The level of a contaminant in thich there is no known or expected IGs are set by the California	contaminan requiremen	Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.				
highest level of a disin There is convincing evil is necessary for control Maximum Residual D The level of a drinkin there is no known or ex	Disinfectant Level (MRDL): The infectant allowed in drinking water, dence that addition of a disinfectant of microbial contaminants. isinfectant Level Goal (MRDLG): may water disinfectant below which expected risk to health. MRDLGs do of the use of disinfectants to control	MCL or n conditions. ND: not de ppm: parts ppb: parts ppt: parts ppt: parts ppq: parts ppq: parts	Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions. ND: not detectable at testing limit ppm: parts per million or milligrams per liter (mg/L) ppb: parts per billion or micrograms per liter (μg/L) ppt: parts per trillion or nanograms per liter (ng/L) ppq: parts per quadrillion or picogram per liter (pg/L) pCi/L: picocuries per liter (a measure of radiation)				

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Microbiological Contaminants	Highest No. of Detections	in Violation		MCL MCL		MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0		More than 1 sample a month with a detection			0	Naturally present in the environment
Fecal Coliform or E. coli	(In the year)		0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>		0	Human and animal fecal waste
TABLE	2 – SAMPLI	NG RESUI	TS SHOW	ING THE DI	ETECTIO	N OF LEA	AD AND COPPER
Lead and Copper (and reporting units)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	06/10/14	35	< 5	0	15	0.2	Internal corrosion of household water plumbing systems; discharge from industrial manufacturers; erosion of natural deposits
Copper (ppm)	06/10/14	35	0.06	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
	TABLE 3	- SAMPL	ING RESU	LTS FOR SO	DDIUM A	ND HARI	ONESS
Chemical or Constituent (and reporting units)		Level F		Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	02/04/14	27		27	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	02/04/14	223		223	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

^{*}Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DET	ECTION (OF CONTA	MINANTS	WITH A P	RIMARY DI	RINKING WATER STANDARD		
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant		
Nitrate as Nitrogen (ppm)	2015	4	3 - 4	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits		
Barium (ppm)	02/04/14	0.1	0.1	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits		
Hexavalent Chromium (ppb)	08/04/14	5	5	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, and textile manufacturing facilities; erosion		
TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD Chemical or Constituent Sample Level Range of MCL PHG Typical Source of Contaminant								
(and reporting units)	Date	Detected	Detections	1	(MCLG)			
Total Dissolved Solids (ppm)	02/04/14	360	360	1000	N/A	Runoff/leaching from natural deposits		
Specific Conductance	02/04/14	455	455	1600	N/A	Substances that form ions when in water; seawater influence		
(umho/cm) Chloride (ppm)	02/04/14	9	9	500	N/A	Runoff/leaching from natural deposits; seawater influence		
Sulfate (ppm)	02/04/14	20	20	500	N/A	Runoff/leaching from natural deposits' industrial wastes		

^{*}Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided below.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Oakdale Irrigation District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Vulnerability Assessment Summary

A source water assessment was conducted for the OID - ID#41 (Mountain View Tract) water system in June of 2002. The source is considered most vulnerable to the following activities not associated with any detected contaminants: animal feeding operations, and septic systems - high density. Recent water quality analyses indicate that this source is in compliance with State Standards. However, the source is still considered vulnerable to activities located near the drinking water source. For more information regarding the assessment summary, contact: Buila at (209) 847-0341.

ATTACHMENT 7

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

Water System Name:		Oakdale Irrigation District's Improvement District No. 41 (Mountain View)								
Water System Number:			5000016							
June the s	20, 20 ystem	016_ (date) certifies that	to customer the inform	rs (and appropriate ne	otices of availability the report is corre	the Report was distributed on whave been given). Further, et and consistent with the e Health.				
Certi	fied by	: Name:		Joe Buila						
Signatu		ıre:	Joseph Mark							
Title:			Water Utilities Technician							
Phone		Number:	umber: (209) 840-5510		Date: 6/20/16					
	ems tha	t apply and fi was distribut	<i>ll-in where</i> ed by mai	appropriate:	livery methods. S	plete the below by checking pecify other direct delivery				
X		food faith" efforts were used to reach non-bill paying consumers. Those efforts included the bllowing methods:								
	X	Posting the (sting the CCR on the Internet at www. oakdaleirrigation.com							
		Mailing the	Mailing the CCR to postal patrons within the service area (attach zip codes used)							
		Advertising	lvertising the availability of the CCR in news media (attach copy of press release)							
			cation of the CCR in a local newspaper of general circulation (attach a copy of the shed notice, including name of newspaper and date published)							
		Posted the C	the CCR in public places (attach a list of locations)							
		Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools								
		Delivery to	community	organizations (attach	a list of organization	ns)				
	For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www									
	For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission									